



MUNICIPAL CORPORATION CHANDIGARH
Public Health Laboratory at Water Works Sector 39

TEST - REPORT

Not for legal use

Ref. No. & Date :- No. GMSSS/BEH/2021/157 Dated 05.07.2021
Issued to :- The Principal,
Govt. Model Sr. Sec. School,
Behlana, UT., Chandigarh.
Quantity of sample :- Approximate 1200 ml.
Date of Collection :- 07.07.2021
Client reference :- Sample collected by Laboratory Staff
Packing of sample :- Sample filled in P.P. and Glass Bottle.
Source of sample :- from School Tap of Govt. Model Sr. Sec. School,
Behlana, UT., Chandigarh.

S. No.	Examination	Quality Standard	Units	Results
1.	Turbidity	<1.0	N.T.U	0.6
2.	pH	7.0-8.5	----	7.42
3.	Residual Chlorine	0.2 - 0.4	mg/L	0.2
4.	Total Alkalinity (as CaCO ₃)	200	-do-	286
5.	Total Hardness (as CaCO ₃)	200	-do-	138
6.	Chlorides (as Cl)	200	-do-	09
7.	Free & Saline Ammonia	Nil	-do-	Nil
8.	Total Dissolved Solids	500	-do-	340
9.	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide Receipt No.07/2021-22/030431, dated 05.07.2021, Amount Rs.3300/-.

Note:- **Water is fit for drinking.**

Lab. No. MCPHL/21/ 2864
Dated: - 09.07.2021

Chemist,
MCPH Laboratory,
Chandigarh

Sub Divisional Engineer,
M.C.P.H. Sub Division No. 2,
Chandigarh

Dated:- 9/7/21

Endst No. MCPHL/21/ _____

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh with reference to your letter Endst. No.MOH/Supdt. Admn./2021/5707 Dated 22.06.2021.

Chemist
MCPH Laboratory
Chandigarh

Sub Divisional Engineer,
M.C.P.H. Sub Division No. 2,
Chandigarh